CESI





TEST REPORT APPROVED B5023261

Client MF TRASFORMATORI S.r.l.

Address of the client Loc. S. Anna 22/24 25011 Calcinato (BS) Italia

Manufacturer MF TRASFORMATORI S.r.l.

Tested samples/items Non-enclosed three-phase dry-type power transformer, with

encapsulated windings, for continuous duty, with cooling by air

natural convection (AN):

Type TReco - 630 kVA - 20 kV / 0,4 kV

Tests carried out Measurement of winding resistance

Measurement of no-load loss and current

Measurement of short-circuit impedance and load loss

Standards/Specifications IEC 60076-11 {Ed.1.0} (2004-05)

Tests date from November 09, 2015 to November 09, 2015

The results reported in this document relate only to the tested samples/items.

Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 12 No. of pages annexed --

Issue date November 09, 2015

Prepared PMV - Mantegazza Vittorio

Verified PSV - Vidori Mauro, PMV - Magistris Paolo

Approved PMI - The Manager - Arcidiaco Lorenzo

Testing & Certification Division
Testing Operations Area
"Milan Platform"
Manager

CESI S.p.A.

Via Rubattino 54 I-20134 Milano - Italy Tel: +39 02 21251 Fax: +39 02 21255440 e-mail: info@cesi.it www.cesi.it Capitale sociale € 8.550.000 interamente versato C.F. e numero iscrizione Reg. Imprese di Milano 00793580150 P.I. IT00793580150 N. R.E.A. 429222

© Copyright 2015 by CESI. All rights reserved

Page1

Approved Page 2

Tests witnessed by

Mr. Morelli MF TRASFORMATORI S.r.l.

Identification of the object not requested

Revision history

Revision No.	Date	List of modifications	
0	09/11/2015	First issue	

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: ---

The measurement uncertainties stated in this Test Report have been determined in accordance with the current Publication EA-4/02.

They are expressed as expanded uncertainty obtained multiplying the standard uncertainty by a coverage factor k = 2, normally corresponding to a confidence level of about 95 %.(CESI procedure B3008625)

> *Voltage a.c.* $\leq \pm 3.0 \%$ Current a.c. $\leq \pm 3.0 \%$

Resistance d.c. $\leq \pm 0.50 \%$

Temperature (with TC type T) $\leq \pm 2.0 \, ^{\circ}C$

Transformer voltage ratio $\leq \pm 0.25 \%$

Time $\leq \pm 2.0 s$

Laboratory information

Receipt date of the sample

CESI - Via Rubattino 54 - Milan **Test location**

CESI testing team Mr. Garanzini

Mr. Carboni

MP3 / P120 **Test laboratory**

Activity code n. order 0070003707

Rated characteristics of the tested object assigned by the Client

Dry-type power transformer Manufacturer	MF TRASFORMATORI S.r.l.
	TReco
Type Manufacturer's serial number	191015/1
Year of manufacturing	2015
Number of phases	3
Rated voltage of the high-voltage winding (primary winding)	$20 \text{ kV} \pm 2 \text{ x } 2,5 \text{ % kV}$
Rated voltage of the low-voltage winding (secondary winding)	20 KV ± 2 X 2,5 % KV
Rated voltage of the low-voltage winding (secondary winding)	20 kV / 0,415 kV
	20 KV / 0,413 KV 50 Hz
Rated frequency	
Rated power	630 kVA
Rated current of the high-voltage winding (primary winding)	18,2 A
Rated current of the low-voltage winding (secondary winding)	876,5 A
Short-circuit impedance	6,0 %
Connection symbol	Dyn11
Cooling method	AN
No load loss	≤ 1100 W
Load loss	≤ 7600 W
Total mass transformer	1865 kg
Characteristics of the windings	
Rated insulation levels	LI 125 AC 50 / AC 3
Insulation class	F/F
Type of construction	with circular concentric coils
High-voltage winding conductor	aluminum strip
Low-voltage winding conductor	metal foil (aluminum)
Maximum temperature rise for 40°C ambiente temperature	100 K / 100 K
Name and signature of Client's witness:	







CESI

Photo no.



3

Photo no.

CESI

Measurement of winding resistance

Measured values


The measurement were performed using winding analyser TETTEX 2293, after the transformer without excitation, for a time higher than three hours.

Date: November 09, 2015

Tap-changer		High-volta	ge winding		Low-voltage winding			
position	resistance measured between terminals			ambient	resistance m	easured betwe	en terminals	ambient
	U-V V-W W-U		temperature	u-v	V-W	w-u	temperature	
-	Ω	Ω	Ω	°C	mΩ	mΩ	mΩ	°C
0	7,293	7,288	7,299	19,9	1,164	1,163	1,172	19,9

Calculated values (by resistance measured between terminals)

Tap-changer	Phase resistance (average value)					
position	of the high-vo	oltage winding	of the low-vo	ltage winding		
	at ambient temperature	at 120 °C	at ambient temperature	at 120°C		
-	Ω	Ω	mΩ	mΩ		
0	10,94	15,41	0,5830	0,8213		



Measurement of no-load loss and current

Measured values

The measurement were performed applying voltage values close to the rated voltage (at rated frequency) to the low-voltage winding and the high-voltage winding open.

Date: November 09, 2015

Measurement effected	V _o	Po	I_{O}
No.	V	W	A
1	422,5	1111,5	5,140
2	419,8	1080,1	4,616
3	416,1	1043,4	4,099
4	414,7	1031,9	3,968
5	410,3	992,3	3,525

Calculated values


The following values were obtained by interpolation of the measured values.

No-load loss P _O	No-load current I _O	
at rated voltage $U_{\rm r}$	at rated voltage U	
W	A	%
1034	3,99	0,46






Measurement of no-load loss



interpolation of the no-load losses measured values



interpolation of the no-load current measured values

Measurement of short-circuit impedance and load loss

Measured values

The measurement were performed supplying the high-voltage winding at current values close to the rated current (at rated frequency) and the low-voltage winding short-circuited.

Date: November 09, 2015

Tap-changer	V_{SC}	I_{SC}	P_{SC}	Ambient
position	(average value)	(average value)	(average value)	Temperature
-	V	A	W	°C
	1076	16,23	4401	
0	1075	16,22	4402	20,0
	1075	16,22	4399	

Calculated values (at rated current)

CHICALOGUE (METAGOR CHITCHE)							
Tap-changer	$R_{SC}I_r$	$X_{SC}I_{r}$	$Z_{SC}I_{r}$	Load loss - P _{SC}			
position	at 120°C	at 120°C	at 120°C	at 120°C			
-	%	%	%	W			
0	1,170	5,964	6,08	7368			





Measurement of short-circuit impedance and load loss

Copper bar (1000x10 mm) short-circuit during measurement of short-circuit impedance and load loss

Laboratory information

 $P118 \, / \, MP3$ Test laboratory: Characteristics of supply circuit

Test	Regulator		Alternator		Transformer	
	type	diagram	type	diagram	type	ratio
routine test	RG3	Y / Ys	-	-	-	-

characteristics of measuring instrumentation

instrument	CESI n°	Calibration Report	Data Acq. Syst
NORMA D5255 T	014002	B5001731	-
HP3497A (1)	006462	B4014315	-
Yokogawa DL850	057031	B5007717	-
NORMA D5255 T(2)	011579	B5001728	-
	013001	B5020128	
CT (10-30-100/5)	013002	B5020128	
	013003	B5020128	NODALA DESECT
	013004	B5021853	NORMA D5255 T
CT (0,5-1-3/5)	013005	B5021853	
	013006	B5021853	
	009440	B0030011	
VT	009441	B0030010	NORMA D5255 T
	009442	B0030008	
-	-	-	NORMA D5255 T(2)-
winding analyser 2293	-	B4016087	Resistance / ratio
-	-	-	HP3497A (1)
	000262	B0030007	
VT	000263	B0030006	-
	013155	B1010409	
main frame + microphones	5644356449	B2040049	-
	NORMA D5255 T HP3497A (1) Yokogawa DL850 NORMA D5255 T(2) CT (10-30-100/5) CT (0,5-1-3/5) VT winding analyser 2293 - VT main frame +	NORMA D5255 T 014002 HP3497A (1) 006462 Yokogawa DL850 057031 NORMA D5255 T(2) 011579 013001 CT (10-30-100/5) 013002 013003 013004 CT (0,5-1-3/5) 013005 013006 VT 009440 VT 009441 009442	NORMA D5255 T 014002 B5001731 HP3497A (1) 006462 B4014315 Yokogawa DL850 057031 B5007717 NORMA D5255 T(2) 011579 B5001728 CT (10-30-100/5) 013002 B5020128 013003 B5020128 013004 B5021853 CT (0,5-1-3/5) 013005 B5021853 O13006 B5021853 O13006 B5021853 O09440 B0030011 VT 009441 B0030010 O09442 B0030008

Measurement of temperatures:

The copper-constantan thermocouples used for measuring the temperatures were previously checked in accordance with CESI procedure NOA A8029278.

Measuring software: SAD P120	Software release: 1.1
------------------------------	-----------------------

